



**Department of
Education**

Carmen Fariña, Chancellor

Elizabeth A. Rose February 13, 2017

Deputy Chancellor

Division of Operations Dear Families and Staff:

**52 Chambers Street
New York, NY 10007**

212 374 7868 Tel

212 374 5588 Fax

This is a follow up to my December 19 letter outlining the additional measures the New York City Department of Education (DOE) is taking to ensure that the water in New York City schools is safe for students and staff.

On **January 28, 2017**, every potential source of water for drinking or preparing food at **P.S./I.S. 323 - Brooklyn** (P.S./I.S. 323, 210 Chester Street Brooklyn, NY 11212) was tested for lead. The laboratory results showed elevated levels of lead in **5 of the 107 samples** of water taken and tested from outlets in the building. A more detailed letter related to the testing for lead at P.S./I.S. 323 - Brooklyn is attached and complete test results are posted on the DOE website.

In any building where lead test results show even one water outlet above the action level of 15 parts per billion, the DOE will implement its standard response protocol, which includes removing any drinking or cooking water fixture outlet from service, flushing all or part of the system to eliminate water sitting in pipes overnight, replacing equipment and re-testing after the equipment is replaced.

Each affected drinking or cooking water fixture at P.S./I.S. 323 - Brooklyn will remain out of service until it is remediated and future testing shows that the water does not have an elevated level of lead. The custodial staff will also continue to flush the P.S./I.S. 323 - Brooklyn water systems on Monday mornings before school starts in order to eliminate water that has been stagnant in pipes over the weekend and to ensure safe drinking water is available for students and staff.

Please visit <http://schools.nyc.gov/AboutUs/schools/watersafety.htm> to learn more about the robust protocol we use to ensure the safety of drinking water in each and every school, as well as to look up water test results for their child's school.

We will keep you updated on the remediation work at P.S./I.S. 323 - Brooklyn, and thank you for your patience and support.

Sincerely yours,

Elizabeth A. Rose



A NOTICE TO PARENTS, GUARDIANS, AND STAFF
P.S./I.S. 323 - Brooklyn
P.S./I.S. 323
210 Chester Street Brooklyn, NY 11212
LEAD TESTING OF SCHOOL DRINKING WATER
February 13, 2017

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 15 parts per billion (ppb), which is equal to 15 micrograms per liter (µg/L), the NYSDOH requires that the school take action to reduce the exposure to lead.

What is first draw testing of school drinking water for lead?

The “on-again, off-again” nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This “first draw” sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

What are the results of the first draw testing?

Samples Collected on 01/28/2017				
Floor	Function / Space	Room	Fixture Type	Sample Results
2	CLASSROOM	232	BUBBLER 1	17.8 ppb
SB	GIRLS LOCKER ROOM	-	BUBBLER 1	17.3 ppb
SB	GIRLS LOCKER ROOM	-	BUBBLER 2	36 ppb
SB	KITCHEN	-	COLD WATER FAUCET 6	22.1 ppb
SB	LOCKER ROOM	B15	COLD WATER FAUCET 1	20.6 ppb

What is being done in response to the results?

Outlets that tested with lead levels above the action level (15 ppb) at P.S./I.S. 323 - Brooklyn have been taken out of service and will be replaced. Each of the affected fixtures will remain out of service until remediation work is completed and future testing provides results below the action level.

What are the health effects of lead?

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

What are the other sources of lead exposure?

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a



**Department of
Education**

Carmen Fariña, Chancellor

number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

Should your child be tested for lead?

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

Do elevated lead levels in school drinking water pose a serious risk to students and staff?

The risk to students and staff is low for many reasons. The elevated lead levels identified by the recent round of water testing are not likely to represent the levels seen throughout the day. The recent testing was conducted on water that had remained in pipes overnight. The lead concentration drops sharply after the first use of the day as stagnant water is cleared from the pipes and new, fresh water is brought in from the water main – which is virtually lead-free. In addition, for most students and staff, the amount of water consumed from a school water source during a school day is likely to be small when compared to total daily water consumption. Many of the elevated water samples came from fixtures that are not typically used for drinking, including bathrooms, slop sinks, and laboratories. Given all of these factors it is unlikely that these elevations represent conditions that would pose a health risk, however, if a person drinks sufficiently large quantities of water at those high levels over long periods of time, the risk increases. Nonetheless, if you are concerned about exposure to lead, talk to your doctor about having you or your child tested for lead poisoning.

Who is at risk for lead poisoning?

Children under 3 years of age are the most susceptible and vulnerable to the health effects of lead. Lead also poses a risk to the developing fetus. Exposure to lead may interfere with a child's growth and development.

What do we know about rates of lead poisoning in NYC children?

Rates of lead poisoning among NYC children have been falling. In 2015, 5,371 New York City children younger than 6 years of age were identified with blood lead levels of 5 mcg/dL or greater. This represents an 18% decline from 2014 when there were 6,550 children with blood lead levels of 5 mcg/dL or greater, and an 86% decline since 2005 when there were 37,344 children with blood lead levels of 5mcg/dL or greater.

Additional Resources

For more information regarding the testing program or sampling results go to:

<http://schools.nyc.gov/AboutUs/schools/watersafety.htm>

For information about lead in school drinking water, go to:

http://www.health.ny.gov/environmental/water/drinking/lead/lead_testing_of_school_drinking_water.htm

<http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html>

For information about NYS Department of Health Lead Poisoning Prevention, go to:

<http://www.health.ny.gov/environmental/lead/>

For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means":

<http://www.health.ny.gov/publications/2526/> (available in ten languages).



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Michael Gelfand
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005**

2/6/2017

Phone: (212) 612-7900
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/2/2017. The results are tabulated on the attached data pages for the following client designated project:

**K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/
WO# 2011248.1061.50.02**

The reference number for these samples is EMSL Order #011700891. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK263SBBB000B14.1F-001 **Collected:** 1/28/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.67	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBBB000B14.2F-002 **Collected:** 1/28/2017 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBBB000B14.3F-003 **Collected:** 1/28/2017 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBBL000000.1B-004 **Collected:** 1/28/2017 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.52	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBBL000000.2B-005 **Collected:** 1/28/2017 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBBL000000.1F-006 **Collected:** 1/28/2017 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.21	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBBL000000.2F-007 **Collected:** 1/28/2017 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.07	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK263SBBL000000.3F-008 **Collected:** 1/28/2017 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.61	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBCF000000.3B-011 **Collected:** 1/28/2017 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBCF000000.4B-012 **Collected:** 1/28/2017 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBCF000000.5B-013 **Collected:** 1/28/2017 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.51	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBCF000000.1F-014 **Collected:** 1/28/2017 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.17	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBCF000000.2F-015 **Collected:** 1/28/2017 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBCF000000.3F-016 **Collected:** 1/28/2017 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK263SBGB000B18.1F-018 **Collected:** 1/28/2017 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.28	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBGB000B18.2F-019 **Collected:** 1/28/2017 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.37	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBGB000B18.3F-020 **Collected:** 1/28/2017 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.67	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBGL000000.1B-021 **Collected:** 1/28/2017 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.3	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBGL000000.2B-022 **Collected:** 1/28/2017 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	36.0	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBGL000000.1F-023 **Collected:** 1/28/2017 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.08	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBGL000000.2F-024 **Collected:** 1/28/2017 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.8	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK263SBGL000000.3F-025 **Collected:** 1/28/2017 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.65	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBHA000B14.1F-026 **Collected:** 1/28/2017 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.65	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBHA000B14.2F-027 **Collected:** 1/28/2017 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.11	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBHA000B14.3F-028 **Collected:** 1/28/2017 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.38	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBHA000B15.1B-029 **Collected:** 1/28/2017 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBHA000B15.2B-030 **Collected:** 1/28/2017 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBHA000B18.1F-031 **Collected:** 1/28/2017 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.60	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK263SBHA000B18.2F-032 **Collected:** 1/28/2017 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.29	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBHA000B18.3F-033 **Collected:** 1/28/2017 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.11	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBK1000000.1F-034 **Collected:** 1/28/2017 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.27	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBK1000000.2F-035 **Collected:** 1/28/2017 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBK1000000.3F-036 **Collected:** 1/28/2017 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBK1000000.4F-037 **Collected:** 1/28/2017 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBK1000000.5F-038 **Collected:** 1/28/2017 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK263SBKI000000.6F-039 **Collected:** 1/28/2017 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	22.1	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBKI000000.7F-040 **Collected:** 1/28/2017 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBKI000000.8F-041 **Collected:** 1/28/2017 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.42	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBKI000000.1S-042 **Collected:** 1/28/2017 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.09	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBLR000B15.1F-045 **Collected:** 1/28/2017 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.6	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK263SBLR000B19.1F-046 **Collected:** 1/28/2017 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.23	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301BR000121.1F-047 **Collected:** 1/28/2017 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.10	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26301BB000114.1F-048 **Collected:** 1/28/2017 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.27	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301BB000114.2F-049 **Collected:** 1/28/2017 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.13	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301BB000114.3F-050 **Collected:** 1/28/2017 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.11	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301CR000106.1B-051 **Collected:** 1/28/2017 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.55	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301CR000106.1F-052 **Collected:** 1/28/2017 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.04	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301CR000148.1F-055 **Collected:** 1/28/2017 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.60	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301CR000148.2F-056 **Collected:** 1/28/2017 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.35	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26301CR000148.3F-057 **Collected:** 1/28/2017 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301GB000118.1F-067 **Collected:** 1/28/2017 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.04	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301GB000118.2F-068 **Collected:** 1/28/2017 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301GB000118.3F-069 **Collected:** 1/28/2017 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301GY000136.1B-070 **Collected:** 1/28/2017 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301GY000136.1F-072 **Collected:** 1/28/2017 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.73	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301HA000108.1B-074 **Collected:** 1/28/2017 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26301HA000108.2B-075 **Collected:** 1/28/2017 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301HA000127.1B-076 **Collected:** 1/28/2017 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301HA000127.2B-077 **Collected:** 1/28/2017 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301HA000140.1B-078 **Collected:** 1/28/2017 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.39	1.00	µg/L	2/2/2017	SM	2/2/2017	EG

Client Sample Description 1CK26301HA000140.2B-079 **Collected:** 1/28/2017 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26301MO000133.1F-080 **Collected:** 1/28/2017 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.04	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26301MO000133.2F-081 **Collected:** 1/28/2017 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.20	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26301OF000125.1F-082 **Collected:** 1/28/2017 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.89	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26301OF000144.1F-084 **Collected:** 1/28/2017 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.35	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26301OF000146.1F-085 **Collected:** 1/28/2017 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.07	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26301TC000110.1F-086 **Collected:** 1/28/2017 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.20	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302BB000214.1F-087 **Collected:** 1/28/2017 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.50	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302BB000214.2F-088 **Collected:** 1/28/2017 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.83	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302BB000214.3F-089 **Collected:** 1/28/2017 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26302CR000204.1F-090 **Collected:** 1/28/2017 **Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.11	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302CR000204.2F-091 **Collected:** 1/28/2017 **Lab ID:** 0072

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302CR000232.1F-093 **Collected:** 1/28/2017 **Lab ID:** 0073

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.7	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302CR000232.2F-094 **Collected:** 1/28/2017 **Lab ID:** 0074

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.98	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302CR000232.3F-095 **Collected:** 1/28/2017 **Lab ID:** 0075

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.8	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302GB000218.1F-096 **Collected:** 1/28/2017 **Lab ID:** 0076

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302GB000218.2F-097 **Collected:** 1/28/2017 **Lab ID:** 0077

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26302GB000218.3F-098 **Collected:** 1/28/2017 **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302HA000208.1B-099 **Collected:** 1/28/2017 **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.55	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302HA000208.2B-100 **Collected:** 1/28/2017 **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.26	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302HA000225.1B-101 **Collected:** 1/28/2017 **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.31	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302HA000225.2B-102 **Collected:** 1/28/2017 **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.53	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302HA000240.1B-103 **Collected:** 1/28/2017 **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.01	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26302HA000240.2B-104 **Collected:** 1/28/2017 **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.23	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700891
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26302TC000210.1F-107 **Collected:** 1/28/2017 **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303BB000314.1F-109 **Collected:** 1/28/2017 **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303BB000314.2F-110 **Collected:** 1/28/2017 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303BB000314.3F-111 **Collected:** 1/28/2017 **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303CR000308.1F-112 **Collected:** 1/28/2017 **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303CR000308.2F-113 **Collected:** 1/28/2017 **Lab ID:** 0090

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303CR000308.3F-114 **Collected:** 1/28/2017 **Lab ID:** 0091

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26303GB000318.1F-118 **Collected:** 1/28/2017 **Lab ID:** 0092

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.71	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303GB000318.2F-119 **Collected:** 1/28/2017 **Lab ID:** 0093

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303GB000318.3F-120 **Collected:** 1/28/2017 **Lab ID:** 0094

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303HA000310.1B-122 **Collected:** 1/28/2017 **Lab ID:** 0095

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303HA000310.2B-123 **Collected:** 1/28/2017 **Lab ID:** 0096

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303HA000327.1B-124 **Collected:** 1/28/2017 **Lab ID:** 0097

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303HA000327.2B-125 **Collected:** 1/28/2017 **Lab ID:** 0098

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description 1CK26303OF000312.1F-128 **Collected:** 1/28/2017 **Lab ID:** 0099

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.33	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303OF000327.1F-129 **Collected:** 1/28/2017 **Lab ID:** 0100

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.90	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303OF000327.2F-130 **Collected:** 1/28/2017 **Lab ID:** 0101

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.91	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description 1CK26303OF000327.3F-131 **Collected:** 1/28/2017 **Lab ID:** 0102

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.81	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description K263-OFFICE-SINK 4-135 **Collected:** 1/28/2017 **Lab ID:** 0103

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.88	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description K263-OFFICE-SINK 5-136 **Collected:** 1/28/2017 **Lab ID:** 0104

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.98	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description K263-ADULT BATHROOM-SINK1-137 **Collected:** 1/28/2017 **Lab ID:** 0105

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.39	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700891

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Michael Gelfand**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 02/02/17 7:00 AM

Project: K263/ P.S./ I.S. 323 - Brooklyn/ 210 Chester Street, Brooklyn, NY/ WO# 2011248.1061.50.02

Analytical Results

Client Sample Description K263-COLD WATER 4-138 **Collected:** 1/28/2017 **Lab ID:** 0106

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Client Sample Description K263-GIRLS LOCKER ROOM-SINK 4-139 **Collected:** 1/28/2017 **Lab ID:** 0107

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.78	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

011700891

CONSULTANT INFORMATION

PROJECT INFORMATION

NON-SAMPLABLE OUTLET LEGEND

Name: MURAT EBIN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

	(ppb)				(ppb)		
1ST COC K263 SB FL BOYS BATHROOM 000B14 COLD WATER FAUCET 1 DATE <u>9/28</u> TIME <u>709</u>			I O T M	1	1ST COC K263 SB FL BOYS LOCKER ROOM 000000 COLD WATER FAUCET 2 DATE <u>9/28</u> TIME <u>720</u>		I O T M 7
1ST COC K263 SB FL BOYS BATHROOM 000B14 COLD WATER FAUCET 2 DATE <u>9/28</u> TIME <u>709</u>			I O T M	2	1ST COC K263 SB FL BOYS LOCKER ROOM 000000 COLD WATER FAUCET 3 DATE <u>9/28</u> TIME <u>720</u>		I O T M 8
1ST COC K263 SB FL BOYS BATHROOM 000B14 COLD WATER FAUCET 3 DATE <u>9/28</u> TIME <u>709</u>			I O T M	3	1ST COC K263 SB FL CAFETERIA 000000 BUBBLER 3 DATE <u>9/28</u> TIME <u>650</u>		I O T M 9
1ST COC K263 SB FL BOYS LOCKER ROOM 000000 BUBBLER 4 <u>SINK 4</u> DATE <u>9/28</u> TIME <u>720</u>			I O T M	4	1ST COC K263 SB FL CAFETERIA 000000 BUBBLER 4 <u>DNE</u> DATE <u>9/28</u> TIME <u>652</u>		I O T M 10
1ST COC K263 SB FL BOYS LOCKER ROOM 000000 BUBBLER 2 <u>BATHROOM SINK</u> DATE <u>9/28</u> TIME <u>720</u>			I O T M	5	1ST COC K263 SB FL CAFETERIA 000000 BUBBLER 5 <u>DNE</u> DATE <u>9/28</u> TIME <u>715</u>		I O T M 11
1ST COC K263 SB FL BOYS LOCKER ROOM 000000 COLD WATER FAUCET 1 DATE <u>9/28</u> TIME <u>720</u>			I O T M	6	1ST COC K263 SB FL CAFETERIA 000000 COLD WATER FAUCET 1 DATE <u>9/28</u> TIME <u>650</u>		I O T M 12

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <u>MURAT EBIN</u>	<u>Fred A. Inf</u>	<u>2-7-17</u>	<u>13:47</u>
2	<u>CP Cowie</u>	<u>2-1-17</u>	<u>7:05P</u>
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Eric Gaskill</u>	Date: <u>2/2/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u> Sample Size: <u>250 mL</u>

rec'd by Steven Lopez on 2/2/17 @ 7:00am 21.1

011700891

CONSULTANT INFORMATION













Name: MURAT ERGEN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

PROJECT INFORMATION

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

		(ppb)			(ppb)	
1ST COC K263 SB FL CAFETERIA 000000 COLD WATER FAUCET 2  DATE <u>9/28</u> TIME <u>650</u>			I O T M	13	1ST COC K263 SB FL GIRLS LOCKER ROOM 000000 BUBBLER 2  DATE <u>9/28</u> TIME <u>717</u>	I O T M
1ST COC K263 SB FL CAFETERIA 000000 COLD WATER FAUCET 3  DATE <u>9/28</u> TIME <u>650</u>			I O T M	14	1ST COC K263 SB FL GIRLS LOCKER ROOM 000000 COLD WATER FAUCET 1  DATE <u>9/28</u> TIME <u>717</u>	I O T M
1ST COC K263 SB FL GIRLS BATHROOM 000B18 COLD WATER FAUCET 1  DATE <u>9/28</u> TIME <u>714</u>			I O T M	15	1ST COC K263 SB FL GIRLS LOCKER ROOM 000000 COLD WATER FAUCET 2  DATE <u>9/28</u> TIME <u>718</u>	I O T M
1ST COC K263 SB FL GIRLS BATHROOM 000B18 COLD WATER FAUCET 2  DATE <u>9/28</u> TIME <u>714</u>			I O T M	16	1ST COC K263 SB FL GIRLS LOCKER ROOM 000000 COLD WATER FAUCET 3  DATE <u>9/28</u> TIME <u>718</u>	I O T M
1ST COC K263 SB FL GIRLS BATHROOM 000B18 COLD WATER FAUCET 3  DATE <u>9/28</u> TIME <u>714</u>			I O T M	17	1ST COC K263 SB FL HALLWAY 000B14 COLD WATER FAUCET 1  DATE <u>9/28</u> TIME <u>710</u>	I O T M
1ST COC K263 SB FL GIRLS LOCKER ROOM 000000 BUBBLER 1  DATE <u>9/28</u> TIME <u>717</u>			I O T M	18	1ST COC K263 SB FL HALLWAY 000B14 COLD WATER FAUCET 2  DATE <u>9/28</u> TIME <u>710</u>	I O T M

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Eric Gastill</u>	Date: <u>2/2/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u> Sample Size: <u>250 mL</u>

rec'd by Steven Lopez on 2/2/17 @ 7:00am 21.1

011700891

CONSULTANT INFORMATION

Name: MURRAY EGIN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

PROJECT INFORMATION

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)			(ppb)
1ST COC K263 SB FL HALLWAY 000B14 COLD WATER FAUCET 3 DATE 01/28 TIME 710	25	I O T M	1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 1 DATE 01/28 TIME 701
1ST COC K263 SB FL HALLWAY 000B15 BUBBLER 1 DATE 01/28 TIME 711	26	I O T M	1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 2 DATE 01/28 TIME 701
1ST COC K263 SB FL HALLWAY 000B15 BUBBLER 2 DATE 01/28 TIME 711	27	I O T M	1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 3 DATE 01/28 TIME 701
1ST COC K263 SB FL HALLWAY 000B18 COLD WATER FAUCET 1 DATE 01/28 TIME 715	28	I O T M	1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 4 DATE 01/28 TIME 702
1ST COC K263 SB FL HALLWAY 000B18 COLD WATER FAUCET 2 DATE 01/28 TIME 715	29	I O T M	1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 5 DATE 01/28 TIME 702
1ST COC K263 SB FL HALLWAY 000B18 COLD WATER FAUCET 3 DATE 01/28 TIME 715	30	I O T M	1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 6 DATE 01/28 TIME 703

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200-8</u>
Analyzed By: <u>Eric Gaskill</u>	Date: <u>2/2/2017</u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u>
	Sample Size: <u>250 mL</u>

rec'd by Steven Lapes on 2/2/17 @ 7:00am 21.1

011700891

CONSULTANT INFORMATION













Name: MURAT EGIN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

PROJECT INFORMATION

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE **I**
 OUT-OF-ORDER **O**
 YELLOW TAG **T**
 MISCELLANEOUS **M**

		(ppb)			(ppb)	
1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 7  DATE 01/28 TIME 705			I O T M		1ST COC K263 01 FL BOYS BATHROOM 000114 COLD WATER FAUCET 1  DATE 01/28 TIME 607	I O T M
1ST COC K263 SB FL KITCHEN 000000 COLD WATER FAUCET 8  DATE 01/28 TIME 705			I O T M	37	1ST COC K263 01 FL BOYS BATHROOM 000114 COLD WATER FAUCET 2  DATE 01/28 TIME 607	I O T M
1ST COC K263 SB FL KITCHEN 000000 SLOP SINK 1  DATE 01/28 TIME 707			I O T M	38	1ST COC K263 01 FL BOYS BATHROOM 000114 COLD WATER FAUCET 3  DATE 01/28 TIME 607	I O T M
1ST COC K263 SB FL LOCKER ROOM 000B15 COLD WATER FAUCET 1  DATE 01/28 TIME 712			I O T M	39	1ST COC K263 01 FL CLASSROOM 000106 BUBBLER 1  DATE 01/28 TIME 612	I O T M
1ST COC K263 SB FL LOCKER ROOM 000B19 COLD WATER FAUCET 1  DATE 01/28 TIME 714			I O T M	40	1ST COC K263 01 FL CLASSROOM 000106 COLD WATER FAUCET 1  DATE 01/28 TIME 612	I O T M
1ST COC K263 01 FL ADULT BATHROOM 000121 COLD WATER FAUCET 1  DATE 01/28 TIME 558			I O T M	41	1ST COC K263 01 FL CLASSROOM 000148 COLD WATER FAUCET 1  DATE 01/28 TIME 633	I O T M

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Eric Gaskill</u>	Date: <u>2/2/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u> Sample Size: <u>250 mL</u>

rec'd by Steven Lopez on 2/2/17 @ 7:00am 21.1

011700891

CONSULTANT INFORMATION

Name: MURAT EGIN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

PROJECT INFORMATION

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

		(ppb)			(ppb)		
1ST COC K263 01 FL CLASSROOM 000148 COLD WATER FAUCET 2  DATE <u>1/28</u> TIME <u>633</u>			I O T M	49	1ST COC K263 01 FL GYMNASIUM 000136 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>616</u>	I O T M	55
1ST COC K263 01 FL CLASSROOM 000148 COLD WATER FAUCET 3  DATE <u>1/28</u> TIME <u>639</u>			I O T M	50	1ST COC K263 01 FL HALLWAY 000108 BUBBLER 1  DATE <u>1/28</u> TIME <u>610</u>	I O T M	56
1ST COC K263 01 FL GIRLS BATHROOM 000118 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>602</u>			I O T M	51	1ST COC K263 01 FL HALLWAY 000108 BUBBLER 2  DATE <u>1/28</u> TIME <u>610</u>	I O T M	57
1ST COC K263 01 FL GIRLS BATHROOM 000118 COLD WATER FAUCET 2  DATE <u>1/28</u> TIME <u>602</u>			I O T M	52	1ST COC K263 01 FL HALLWAY 000127 BUBBLER 1  DATE <u>1/28</u> TIME <u>553</u>	I O T M	58
1ST COC K263 01 FL GIRLS BATHROOM 000118 COLD WATER FAUCET 3  DATE <u>1/28</u> TIME <u>603</u>			I O T M	53	1ST COC K263 01 FL HALLWAY 000127 BUBBLER 2  DATE <u>1/28</u> TIME <u>552</u>	I O T M	59
1ST COC K263 01 FL GYMNASIUM 000136 BUBBLER 1  DATE <u>1/28</u> TIME <u>618</u>			I O T M	54	1ST COC K263 01 FL HALLWAY 000140 BUBBLER 1  DATE <u>1/28</u> TIME <u>635</u>	I O T M	60

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Eric Gaskill</u>	Date: <u>2/2/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u> Sample Size: <u>250 mL</u>

rec'd by Steven Lopez on 2/2/17 @ 7:00am 21.1

011700891

CONSULTANT INFORMATION

PROJECT INFORMATION

NON-SAMPLABLE OUTLET LEGEND

Name: MURPAT EDEN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

	(ppb)			(ppb)					
1ST COC K263 01 FL HALLWAY 000140 BUBBLER 2 DATE 1/28 TIME 635			I O T M	61	1ST COC K263 01 FL TEACHERS CAFETERIA 000110 COLD WATER FAUCET 1 DATE 1/28 TIME 615			I O T M	67
1ST COC K263 01 FL MEDICAL OFFICE 000133 COLD WATER FAUCET 1 DATE 1/28 TIME 555			I O T M	62	1ST COC K263 02 FL BOYS BATHROOM 000214 COLD WATER FAUCET 1 DATE 1/28 TIME 533			I O T M	68
1ST COC K263 01 FL MEDICAL OFFICE 000133 COLD WATER FAUCET 2 DATE 1/28 TIME 555			I O T M	63	1ST COC K263 02 FL BOYS BATHROOM 000214 COLD WATER FAUCET 2 DATE 1/28 TIME 533			I O T M	69
1ST COC K263 01 FL OFFICE 000125 COLD WATER FAUCET 1 DATE 1/28 TIME 554			I O T M	64	1ST COC K263 02 FL BOYS BATHROOM 000214 COLD WATER FAUCET 3 DATE 1/28 TIME 534			I O T M	70
1ST COC K263 01 FL OFFICE 000144 COLD WATER FAUCET 1 DATE 1/28 TIME 630			I O T M	65	1ST COC K263 02 FL CLASSROOM 000204 COLD WATER FAUCET 1 DATE 1/28 TIME 539			I O T M	71
1ST COC K263 01 FL OFFICE 000146 COLD WATER FAUCET 1 DATE 1/28 TIME 631			I O T M	66	1ST COC K263 02 FL CLASSROOM 000204 COLD WATER FAUCET 2 DATE 1/28 TIME 539			I O T M	72

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Barbra Biddle</u>	Date: <u>2/2/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u> Sample Size: <u>250 ml</u>

rec'd by Awen Lopez on 2/2/17 @ 7:00am 21.1

011700891

CONSULTANT INFORMATION

PROJECT INFORMATION

NON-SAMPLABLE OUTLET LEGEND

Name: MURBAT EGIN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)	I O T M	(ppb)	I O T M
1ST COC K263 02 FL CLASSROOM 000232 COLD WATER FAUCET 1 DATE 1/28 TIME 527	73	1ST COC K263 02 FL HALLWAY 000208 BUBBLER 1 DATE 1/28 TIME 538	79
1ST COC K263 02 FL CLASSROOM 000232 COLD WATER FAUCET 2 DATE 1/28 TIME 526	74	1ST COC K263 02 FL HALLWAY 000208 BUBBLER 2 DATE 1/28 TIME 538	80
1ST COC K263 02 FL CLASSROOM 000232 COLD WATER FAUCET 3 DATE 1/28 TIME 525	75	1ST COC K263 02 FL HALLWAY 000225 BUBBLER 1 DATE 1/28 TIME 524	81
1ST COC K263 02 FL GIRLS BATHROOM 000218 COLD WATER FAUCET 1 DATE 1/28 TIME 530	76	1ST COC K263 02 FL HALLWAY 000225 BUBBLER 2 DATE 1/28 TIME 524	82
1ST COC K263 02 FL GIRLS BATHROOM 000218 COLD WATER FAUCET 2 DATE 1/28 TIME 530	77	1ST COC K263 02 FL HALLWAY 000240 BUBBLER 1 DATE 1/28 TIME 540	83
1ST COC K263 02 FL GIRLS BATHROOM 000218 COLD WATER FAUCET 3 DATE 1/28 TIME 530	78	1ST COC K263 02 FL HALLWAY 000240 BUBBLER 2 DATE 1/28 TIME 540	84

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Barbra Biddle</u>	Date: <u>2/2/2017</u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u>
	Sample Size: <u>250 mL</u>

rec'd by Steven Japes on 2/2/17 @ 7:00am 2/1

011700891

CONSULTANT INFORMATION













Name: M. Gelfand
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

PROJECT INFORMATION

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

		(ppb)			(ppb)		
1ST COC K263 02 FL TEACHERS CAFETERIA 000210 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>539</u>				I O T M 85	1ST COC K263 03 FL CLASSROOM 000308 COLD WATER FAUCET 3  DATE <u>1/28</u> TIME <u>510</u>		I O T M 91
1ST COC K263 03 FL BOYS BATHROOM 000314 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>503</u>				I O T M 86	1ST COC K263 03 FL GIRLS BATHROOM 000318 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>500</u>		I O T M 92
1ST COC K263 03 FL BOYS BATHROOM 000314 COLD WATER FAUCET 2  DATE <u>1/28</u> TIME <u>503</u>				I O T M 87	1ST COC K263 03 FL GIRLS BATHROOM 000318 COLD WATER FAUCET 2  DATE <u>1/28</u> TIME <u>500</u>		I O T M 93
1ST COC K263 03 FL BOYS BATHROOM 000314 COLD WATER FAUCET 3  DATE <u>1/28</u> TIME <u>503</u>				I O T M 88	1ST COC K263 03 FL GIRLS BATHROOM 000318 COLD WATER FAUCET 3  DATE <u>1/28</u> TIME <u>500</u>		I O T M 94
1ST COC K263 03 FL CLASSROOM 000308 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>510</u>				I O T M 89	1ST COC K263 03 FL HALLWAY 000310 BUBBLER 1  DATE <u>1/28</u> TIME <u>510</u>		I O T M 95
1ST COC K263 03 FL CLASSROOM 000308 COLD WATER FAUCET 2  DATE <u>1/28</u> TIME <u>510</u>				I O T M 90	1ST COC K263 03 FL HALLWAY 000310 BUBBLER 2  DATE <u>1/28</u> TIME <u>510</u>		I O T M 96

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Barbra Biddle</u>	Date: <u>2/2/2017</u> Time:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u> Sample Size: <u>250 mL</u>

rec'd by Steven Lopez on 2/2/17 @ 7:00am 21.1

011700891

CONSULTANT INFORMATION







Name: MULBART EGEN
 Address: Louis Berger, 48 Wall Street, NY, NY
 Project Manager: M. Gelfand

PROJECT INFORMATION

BLDG ID: K263
 BLDG Name: P.S./I.S. 323 - BROOKLYN
 Address: 210 CHESTER STREET, BROOKLYN, NY
 WO # 2011248.1061.50.02

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

	(ppb)			(ppb)		
1ST COC K263 03 FL HALLWAY 000327 BUBBLER 1  DATE <u>1/28</u> TIME <u>450</u>		I O T M	97	1ST COC K263 03 OFFICE 327/454 sink 4 Sample 135 01/28	I O T M	103
1ST COC K263 03 FL HALLWAY 000327 BUBBLER 2  DATE <u>1/28</u> TIME <u>450</u>		I O T M	98	1ST COC K263 03 OFFICE 327/454 sink 5 sample 136 01/28	I O T M	104
1ST COC K263 03 FL OFFICE 000312 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>557</u>		I O T M	99	1ST COC K263 Adult BATH/ROOM 128 Sample 137 137 SINK 1 01/28 6:00am	I O T M	105
1ST COC K263 03 FL OFFICE 000327 COLD WATER FAUCET 1  DATE <u>1/28</u> TIME <u>455</u>		I O T M	100	1ST COC K263 SAMPLE 138 - 148. COLD WATER 4 01/28 6:34	I O T M	106
1ST COC K263 03 FL OFFICE 000327 COLD WATER FAUCET 2  DATE <u>1/28</u> TIME <u>455</u>		I O T M	101	1ST COC K263 Sample 139 GIRLS LOCKER ROOM SINK 4 01/28 7:19am	I O T M	107
1ST COC K263 03 FL OFFICE 000327 COLD WATER FAUCET 3  DATE <u>1/28</u> TIME <u>455</u>		I O T M	102		I O T M	

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

TURN AROUND TIME: 1 WEEK

LABORATORY INFORMATION

Laboratory Name: <u>EMSL Analytical</u>	Method of Analysis: <u>200-8</u>
Analyzed By: <u>Barbra Biddle</u>	Date: <u>2/2/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>HNO3</u> Sample Size: <u>250 mL</u>

rec'd by Steven Lopez on 2/2/17 @ 7:00am 21-1