



**Department of
Education**

Carmen Fariña, Chancellor

Elizabeth A. Rose February 8, 2017

Deputy Chancellor

Division of Operations Dear Families and Staff:

**52 Chambers Street
New York, NY 10007**

212 374 7868 Tel

212 374 5588 Fax

This is a follow up to my December 19 letter outlining the additional measures the New York City Department of Education (DOE) is taking to ensure that the water in New York City schools is safe for students and staff.

On **January 26, 2017**, every potential source of water for drinking or preparing food at **P.S. 144 - Queens** (P.S. 144 Col Jeromus Remsen, 93-02 69 Avenue Queens, NY 11375) was tested for lead. The laboratory results showed elevated levels of lead in **3 of the 48 samples** of water taken and tested from outlets in the building. A more detailed letter related to the testing for lead at P.S. 144 - Queens is attached and complete test results are posted on the DOE website.

In any building where lead test results show even one water outlet above the action level of 15 parts per billion, the DOE will implement its standard response protocol, which includes removing any drinking or cooking water fixture outlet from service, flushing all or part of the system to eliminate water sitting in pipes overnight, replacing equipment and re-testing after the equipment is replaced.

Each affected drinking or cooking water fixture at P.S. 144 - Queens will remain out of service until it is remediated and future testing shows that the water does not have an elevated level of lead. The custodial staff will also continue to flush the P.S. 144 - Queens water systems on Monday mornings before school starts in order to eliminate water that has been stagnant in pipes over the weekend and to ensure safe drinking water is available for students and staff.

Please visit <http://schools.nyc.gov/AboutUs/schools/watersafety.htm> to learn more about the robust protocol we use to ensure the safety of drinking water in each and every school, as well as to look up water test results for their child's school.

We will keep you updated on the remediation work at P.S. 144 - Queens, and thank you for your patience and support.

Sincerely yours,

Elizabeth A. Rose



A NOTICE TO PARENTS, GUARDIANS, AND STAFF

P.S. 144 - Queens

P.S. 144 Col Jeromus Remsen

93-02 69 Avenue Queens, NY 11375

LEAD TESTING OF SCHOOL DRINKING WATER

February 8, 2017

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 15 parts per billion (ppb), which is equal to 15 micrograms per liter (µg/L), the NYSDOH requires that the school take action to reduce the exposure to lead.

What is first draw testing of school drinking water for lead?

The “on-again, off-again” nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This “first draw” sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

What are the results of the first draw testing?

Samples Collected on 01/26/2017				
Floor	Function / Space	Room	Fixture Type	Sample Results
01	BOYS BATHROOM	157	COLD WATER FAUCET 1	180 ppb
01	CAFETERIA	157	BUBBLER 1	28 ppb
04	ADULT BATHROOM	457	COLD WATER FAUCET 1	21 ppb

What is being done in response to the results?

Outlets that tested with lead levels above the action level (15 ppb) at P.S. 144 - Queens have been taken out of service and will be replaced. Each of the affected fixtures will remain out of service until remediation work is completed and future testing provides results below the action level.

What are the health effects of lead?

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

What are the other sources of lead exposure?

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead

exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

Should your child be tested for lead?

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

Do elevated lead levels in school drinking water pose a serious risk to students and staff?

The risk to students and staff is low for many reasons. The elevated lead levels identified by the recent round of water testing are not likely to represent the levels seen throughout the day. The recent testing was conducted on water that had remained in pipes overnight. The lead concentration drops sharply after the first use of the day as stagnant water is cleared from the pipes and new, fresh water is brought in from the water main – which is virtually lead-free. In addition, for most students and staff, the amount of water consumed from a school water source during a school day is likely to be small when compared to total daily water consumption. Many of the elevated water samples came from fixtures that are not typically used for drinking, including bathrooms, slop sinks, and laboratories. Given all of these factors it is unlikely that these elevations represent conditions that would pose a health risk, however, if a person drinks sufficiently large quantities of water at those high levels over long periods of time, the risk increases. Nonetheless, if you are concerned about exposure to lead, talk to your doctor about having you or your child tested for lead poisoning.

Who is at risk for lead poisoning?

Children under 3 years of age are the most susceptible and vulnerable to the health effects of lead. Lead also poses a risk to the developing fetus. Exposure to lead may interfere with a child's growth and development.

What do we know about rates of lead poisoning in NYC children?

Rates of lead poisoning among NYC children have been falling. In 2015, 5,371 New York City children younger than 6 years of age were identified with blood lead levels of 5 mcg/dL or greater. This represents an 18% decline from 2014 when there were 6,550 children with blood lead levels of 5 mcg/dL or greater, and an 86% decline since 2005 when there were 37,344 children with blood lead levels of 5mcg/dL or greater.

Additional Resources

For more information regarding the testing program or sampling results go to:

<http://schools.nyc.gov/AboutUs/schools/watersafety.htm>

For information about lead in school drinking water, go to:

http://www.health.ny.gov/environmental/water/drinking/lead/lead_testing_of_school_drinking_water.htm

<http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html>

For information about NYS Department of Health Lead Poisoning Prevention, go to:

<http://www.health.ny.gov/environmental/lead/>

For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means":

<http://www.health.ny.gov/publications/2526/> (available in ten languages).

Client: NYC SCA
 30-30 Thompson Avenue
 Long Island City, NY 11101

Report No.: 2170461
Project No.: 48426
Lab Batch: C11891


Project: Q144
 93-02 69 Ave.
 Queens, NY

Sampled: 01/26/2017
Received: 01/26/2017
Analyzed: 01/27/2017
Reported: 01/27/2017

**Analytical Report for
 Lead in Potable Water by EPA 200.9**

Lab ID#	Catalog ID	Floor	Function/Space	Closest/ Room	Fixture Type	Sample Type	MDL (µg/L)	Lead (µg/L)
1	Q14401BR000118.1F-001	01	ADULT BATHROOM	118	COLD WATER FAUCET 1	Initial	1.0	<1.0
2	Q14401BR000159.1F-002	01	ADULT BATHROOM	159, KITCHEN HELP LOCKER ROM	COLD WATER FAUCET 1	Initial	1.0	<1.0
3	Q14401BB000157.1F-003	01	BOYS BATHROOM	157	COLD WATER FAUCET 1	Initial	1.0	180*
4	Q14401CF000157.1B-006	01	CAFETERIA	157	BUBBLER 1	Initial	1.0	28
5	Q14401CR000103.1F-007	01	CLASSROOM	103	COLD WATER FAUCET 1	Initial	1.0	<1.0
6	Q14401CR000105.1F-008	01	CLASSROOM	105	COLD WATER FAUCET 1	Initial	1.0	<1.0
7	Q14401CR000117.1F-009	01	CLASSROOM	117	COLD WATER FAUCET 1	Initial	1.0	<1.0
8	Q14401GB000155.1F-010	01	GIRLS BATHROOM	155	COLD WATER FAUCET 1	Initial	1.0	<1.0
9	Q14401GB000155.2F-011	01	GIRLS BATHROOM	155	COLD WATER FAUCET 2	Initial	1.0	1.0
10	Q14401GB000160.1F-012	01	GIRLS BATHROOM	160	COLD WATER FAUCET 1	Initial	1.0	2.0

*Result exceeds the highest calibration standard.



 Li Tsang
 Laboratory Director

LT:ns

The analytical results relate only to the samples tested in the condition received by the laboratory. This report must not be reproduced except in its entirety unless with the laboratory's written approval.

Client: NYC SCA
 30-30 Thompson Avenue
 Long Island City, NY 11101

Report No.: 2170461
Project No.: 48426
Lab Batch: C11891

Project: Q144
 93-02 69 Ave.
 Queens, NY

Sampled: 01/26/2017
Received: 01/26/2017
Analyzed: 01/27/2017
Reported: 01/27/2017

**Analytical Report for
 Lead in Potable Water by EPA 200.9**

Lab ID#	Catalog ID	Floor	Function/Space	Closest/ Room	Fixture Type	Sample Type	MDL (µg/L)	Lead (µg/L)
11	Q14401GB000160.2F-013	01	GIRLS BATHROOM	160	COLD WATER FAUCET 2	Initial	1.0	2.2
12	Q14401KI000161.2F-016	01	KITCHEN	161, WEST	COLD WATER FAUCET 2	Initial	1.0	<1.0
13	Q14401KI000161.3F-017	01	KITCHEN	161, NORTH	COLD WATER FAUCET 3	Initial	1.0	<1.0
14	Q14401KI000161.4F-018	01	KITCHEN	161, NORTH	COLD WATER FAUCET 4	Initial	1.0	<1.0
15	Q14402BR000257.1F-019	02	ADULT BATHROOM	257, PRINCIPALS BATHROOM	COLD WATER FAUCET 1	Initial	1.0	<1.0
16	Q14402BR000258.1F-020	02	ADULT BATHROOM	258	COLD WATER FAUCET 1	Initial	1.0	<1.0
17	Q14402BB000260.1F-021	02	BOYS BATHROOM	260	COLD WATER FAUCET 1	Initial	1.0	3.8
18	Q14402CR000201.1B-022	02	CLASSROOM	201	BUBBLER 1	Initial	1.0	<1.0
19	Q14402CR000201.1F-023	02	CLASSROOM	201	COLD WATER FAUCET 1	Initial	1.0	1.3
20	Q14402CR000202.1F-024	02	CLASSROOM	202	COLD WATER FAUCET 1	Initial	1.0	<1.0

*Result exceeds the highest calibration standard.



 Li Tsang
 Laboratory Director

LT:ns

The analytical results relate only to the samples tested in the condition received by the laboratory. This report must not be reproduced except in its entirety unless with the laboratory's written approval.

Client: NYC SCA
 30-30 Thompson Avenue
 Long Island City, NY 11101

Report No.: 2170461
Project No.: 48426
Lab Batch: C11891

Project: Q144
 93-02 69 Ave.
 Queens, NY

Sampled: 01/26/2017
Received: 01/26/2017
Analyzed: 01/27/2017
Reported: 01/27/2017

**Analytical Report for
 Lead in Potable Water by EPA 200.9**

Lab ID#	Catalog ID	Floor	Function/Space	Closest/ Room	Fixture Type	Sample Type	MDL (µg/L)	Lead (µg/L)
21	Q14402CR000205.1B-025	02	CLASSROOM	205	BUBBLER 1	Initial	1.0	<1.0
22	Q14402CR000205.1F-026	02	CLASSROOM	205	COLD WATER FAUCET 1	Initial	1.0	11
23	Q14402CR000213.1F-027	02	CLASSROOM	213	COLD WATER FAUCET 1	Initial	1.0	<1.0
24	Q14402CR000215.1F-028	02	CLASSROOM	215	COLD WATER FAUCET 1	Initial	1.0	<1.0
25	Q14402CR000217.1F-029	02	CLASSROOM	217	COLD WATER FAUCET 1	Initial	1.0	2.5
26	Q14402CR000219.1F-030	02	CLASSROOM	219	COLD WATER FAUCET 1	Initial	1.0	2.0
27	Q14402HA000201.1B-031	02	HALLWAY	201	BUBBLER 1	Initial	1.0	<1.0
28	Q14402HA000263.1B-032	02	HALLWAY	263	BUBBLER 1	Initial	1.0	<1.0
29	Q14402MO000263.1F-033	02	MEDICAL OFFICE	263	COLD WATER FAUCET 1	Initial	1.0	<1.0
30	Q14402TC000262.1F-034	02	TEACHERS CAFETERIA	262	COLD WATER FAUCET 1	Initial	1.0	<1.0

*Result exceeds the highest calibration standard.



 Li Tsang
 Laboratory Director

LT:ns

The analytical results relate only to the samples tested in the condition received by the laboratory. This report must not be reproduced except in its entirety unless with the laboratory's written approval.

Client: NYC SCA
 30-30 Thompson Avenue
 Long Island City, NY 11101

Report No.: 2170461
Project No.: 48426
Lab Batch: C11891

Project: Q144
 93-02 69 Ave.
 Queens, NY

Sampled: 01/26/2017
Received: 01/26/2017
Analyzed: 01/27/2017
Reported: 01/27/2017

**Analytical Report for
 Lead in Potable Water by EPA 200.9**

Lab ID#	Catalog ID	Floor	Function/Space	Closest/ Room	Fixture Type	Sample Type	MDL (µg/L)	Lead (µg/L)
31	Q14403BR000356.1F-035	03	ADULT BATHROOM	356	COLD WATER FAUCET 1	Initial	1.0	<1.0
32	Q14403BB000351.1F-036	03	BOYS BATHROOM	351	COLD WATER FAUCET 1	Initial	1.0	<1.0
33	Q14403GB000358.1F-039	03	GIRLS BATHROOM	358	COLD WATER FAUCET 1	Initial	1.0	1.5
34	Q14403GB000358.2F-040	03	GIRLS BATHROOM	358	COLD WATER FAUCET 2	Initial	1.0	3.3
35	Q14403GB000358.3F-041	03	GIRLS BATHROOM	358	COLD WATER FAUCET 3	Initial	1.0	<1.0
36	Q14403HA000302.1B-042	03	HALLWAY	302	BUBBLER 1	Initial	1.0	<1.0
37	Q14403HA000360.1B-043	03	HALLWAY	360	BUBBLER 1	Initial	1.0	<1.0
38	Q14403OF000354.1F-044	03	OFFICE	354, SPEECH ROOM	COLD WATER FAUCET 1	Initial	1.0	<1.0
39	Q14403OF000359.1F-045	03	OFFICE	359	COLD WATER FAUCET 1	Initial	1.0	<1.0
40	Q14404BR000457.1F-046	04	ADULT BATHROOM	457	COLD WATER FAUCET 1	Initial	1.0	21

*Result exceeds the highest calibration standard.



 Li Tsang
 Laboratory Director

LT:ns

The analytical results relate only to the samples tested in the condition received by the laboratory. This report must not be reproduced except in its entirety unless with the laboratory's written approval.

Client: NYC SCA
 30-30 Thompson Avenue
 Long Island City, NY 11101

Report No.: 2170461
Project No.: 48426
Lab Batch: C11891


Project: Q144
 93-02 69 Ave.
 Queens, NY

Sampled: 01/26/2017
Received: 01/26/2017
Analyzed: 01/27/2017
Reported: 01/27/2017

**Analytical Report for
 Lead in Potable Water by EPA 200.9**

Lab ID#	Catalog ID	Floor	Function/Space	Closest/ Room	Fixture Type	Sample Type	MDL (µg/L)	Lead (µg/L)
41	Q14404BB000451.1F-047	04	BOYS BATHROOM	451	COLD WATER FAUCET 1	Initial	1.0	11
42	Q14404BB000459.1F-048	04	BOYS BATHROOM	459	COLD WATER FAUCET 1	Initial	1.0	3.4
43	Q14404BB000459.2F-049	04	BOYS BATHROOM	459	COLD WATER FAUCET 2	Initial	1.0	2.5
44	Q14404BB000459.3F-050	04	BOYS BATHROOM	459	COLD WATER FAUCET 3	Initial	1.0	<1.0
45	Q14404CR000419.1F-051	04	CLASSROOM	419	COLD WATER FAUCET 1	Initial	1.0	<1.0
46	Q14404GY000454.1F-052	04	GYMNASIUM	454, GYM OFFICE	COLD WATER FAUCET 1	Initial	1.0	<1.0
47	Q14404HA000461.1B-054	04	HALLWAY	461	BUBBLER 1	Initial	1.0	1.1
48	Q14404OF000460.1F-057	04	OFFICE	460	COLD WATER FAUCET 1	Initial	1.0	2.1

*Result exceeds the highest calibration standard.



 Li Tsang
 Laboratory Director

LT:ns

The analytical results relate only to the samples tested in the condition received by the laboratory. This report must not be reproduced except in its entirety unless with the laboratory's written approval.

1 acidified
11/26/17
NY ENVIRONMENTAL
88 HARBOR ROAD PORT WASHINGTON, NY 11050

CONSULTANT INFORMATION

PROJECT INFORMATION

NON-SAMPLABLE OUTLET LEGEND

Name: New York Environmental
Address: 88 Harbor Road Pt Wash
Project Manager: Baudo

BLDG ID: q144
BLDG Name: P.S. 144 - QUEENS
Address: 93-02 69 AVENUE, QUEENS, NY
WO # 48426

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

	(ppb)	I	O	T	M		(ppb)	I	O	T	M
1 1ST COC Q144 01 FL ADULT BATHROOM 000118 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0231	1 <1.0					1ST COC Q144 01 FL CLASSROOM 000103 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0241	1 <1.0				
2 1ST COC Q144 01 FL ADULT BATHROOM 000159 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0246	2 ↓					1ST COC Q144 01 FL CLASSROOM 000105 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0239	2 ↓				
3 1ST COC Q144 01 FL BOYS BATHROOM 000157 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0234	3 180*					1ST COC Q144 01 FL CLASSROOM 000117 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0226	3 ↓				
4 yellow tag	4 ✓					1ST COC Q144 01 FL GIRLS BATHROOM 000155 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0243	4 ↓				
5 yellow tag	5 ✓					1ST COC Q144 01 FL GIRLS BATHROOM 000155 COLD WATER FAUCET 2 DATE 1-26-17 TIME 0245	5 1.0				
6 1ST COC Q144 01 FL CAFETERIA 000157 BUBBLER 1 DATE 1-26-17 TIME 0238	6 28					1ST COC Q144 01 FL GIRLS BATHROOM 000160 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0210	6 2.0				

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date: 1-26-17	Time: 9am
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: NY ENVIRONMENTAL	Method of Analysis: 200.9 REV 2.2
Analyzed By: <u>Wai S Cheny</u>	Date: <u>1/27/17</u> Time: <u>1700</u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: None Sample Size: 250 mL

2170461

C 1 1 8 9 1

NY ENVIRONMENTAL
88 HARBOR ROAD PORT WASHINGTON, NY 11050

CONSULTANT INFORMATION

Name: New York Environmental
Address: 88 Harbor Road Pt Wash
Project Manager: Baudo

PROJECT INFORMATION

BLDG ID: q144
BLDG Name: P.S. 144 - QUEENS
Address: 93-02 69 AVENUE, QUEENS, NY
WO # 48426

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

	(ppb)					(ppb)			
13		1ST COC Q144 01 FL GIRLS BATHROOM 000160 COLD WATER FAUCET 2 11 DATE 1-26-17 TIME 0212	2.2		I O T M		1ST COC Q144 02 FL ADULT BATHROOM 000257 COLD WATER FAUCET 1 15 DATE 1-26-17 TIME 0256	1.0	19
14		yellow tag			I O T M		1ST COC Q144 02 FL ADULT BATHROOM 000258 COLD WATER FAUCET 1 14 DATE 1-26-17 TIME 0303		20
15		out of service			I O T M		1ST COC Q144 02 FL BOYS BATHROOM 000260 COLD WATER FAUCET 1 17 DATE 1-26-17 TIME 0305	3.8	21
16		1ST COC Q144 01 FL KITCHEN 000161 COLD WATER FAUCET 2 12 DATE 1-26-17 TIME 0218	1.0		I O T M		1ST COC Q144 02 FL CLASSROOM 000201 BUBBLER 1 18 DATE 1-26-17 TIME 0256	1.0	22
17		1ST COC Q144 01 FL KITCHEN 000161 COLD WATER FAUCET 3 13 DATE 1-26-17 TIME 0220			I O T M		1ST COC Q144 02 FL CLASSROOM 000201 COLD WATER FAUCET 1 19 DATE 1-26-17 TIME 0257	1.3	23
18		1ST COC Q144 01 FL KITCHEN 000161 COLD WATER FAUCET 4 14 DATE 1-26-17 TIME 0222			I O T M		1ST COC Q144 02 FL CLASSROOM 000202 COLD WATER FAUCET 1 20 DATE 1-26-17 TIME 0255	1.0	24

Relinquished By:	Received By:	Date:	Time:
<i>W</i>	<i>[Signature]</i>	1-26-17	9:00
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <u>NY ENVIRONMENTAL</u>	Method of Analysis: <u>200.9 REV 2.2</u>
Analyzed By: <u>Nat. S. Cheny</u>	Date: <u>1/27/17</u> Time: <u>1700</u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>None</u> Sample Size: <u>250 mL</u>

3

NY ENVIRONMENTAL
88 HARBOR ROAD PORT WASHINGTON, NY 11050

CONSULTANT INFORMATION

Name: New York Environmental
Address: 88 Harbor Road Pt Wash
Project Manager: Baudo

PROJECT INFORMATION

BLDG ID: q144
BLDG Name: P.S. 144 - QUEENS
Address: 93-02 69 AVENUE, QUEENS, NY
WO # 48426

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

	(ppb)				(ppb)			
25	1ST COC Q144 02 FL CLASSROOM 000205 BUBBLER 1 DATE 1-26-17 TIME 0259	21	11.0	I O T M	1ST COC Q144 02 FL HALLWAY 000201 BUBBLER 1 DATE 1-26-17 TIME 0252	27	11.0	I O T M 31
26	1ST COC Q144 02 FL CLASSROOM 000205 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0300	22	11	I O T M	1ST COC Q144 02 FL HALLWAY 000263 BUBBLER 1 DATE 1-26-17 TIME 0318	28		I O T M 32
27	1ST COC Q144 02 FL CLASSROOM 000213 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0309	23	11.0	I O T M	1ST COC Q144 02 FL MEDICAL OFFICE 000263 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0317	29		I O T M 33
28	1ST COC Q144 02 FL CLASSROOM 000215 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0311	24	↓	I O T M	1ST COC Q144 02 FL TEACHERS CAFETERIA 000262 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0307	30		I O T M 34
29	1ST COC Q144 02 FL CLASSROOM 000217 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0313	25	2.5	I O T M	1ST COC Q144 03 FL ADULT BATHROOM 000356 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0328	31		I O T M 35
30	1ST COC Q144 02 FL CLASSROOM 000219 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0315	26	2.0	I O T M	1ST COC Q144 03 FL BOYS BATHROOM 000351 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0340	32		I O T M 36
1	Received By: <u>[Signature]</u>		Date: <u>1-26-17</u>		Time: <u>900</u>			
2								
3								

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <u>NY ENVIRONMENTAL</u>	Method of Analysis: <u>200.9 REV 2.2</u>
Analyzed By: <u>W.A. S. Cherry</u>	Date: <u>1/27/17</u> Time: <u>1700</u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>None</u> Sample Size: <u>250 mL</u>

4

NY ENVIRONMENTAL
88 HARBOR ROAD PORT WASHINGTON, NY 11050

CONSULTANT INFORMATION

PROJECT INFORMATION

NON-SAMPLABLE OUTLET LEGEND

Name: New York Environmental
Address: 88 Harbor Road Pt Wash
Project Manager: Baudo

BLDG ID: q144
BLDG Name: P.S. 144 - QUEENS
Address: 93-02 69 AVENUE, QUEENS, NY
WO # 48426

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

	(ppb)				(ppb)		
37		out of service		1ST COC Q144 03 FL HALLWAY 000360 BUBBLER 1	37	11.0	
38		out of service		1ST COC Q144 03 FL OFFICE 000354 COLD WATER FAUCET 1	38		
39	1.5			1ST COC Q144 03 FL GIRLS BATHROOM 000358 COLD WATER FAUCET 1	39		
40	3.3			1ST COC Q144 04 FL ADULT BATHROOM 000457 COLD WATER FAUCET 1	40	21	
41	<1.0			1ST COC Q144 04 FL BOYS BATHROOM 000451 COLD WATER FAUCET 1	41	11	
42				1ST COC Q144 04 FL BOYS BATHROOM 000459 COLD WATER FAUCET 1	42	3.4	

Reinquised by:	Received By:	Date:	Time:
<i>[Signature]</i>	<i>[Signature]</i>	1-26-18	9:00
1			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: NY ENVIRONMENTAL	Method of Analysis: 200.9 REV 2.2
Analyzed By: <i>Waisley</i>	Date: 1/27/18
Note: No sample submitted if "I", "O", "T", or "M" check-marked	Time: 1700
	Preservative: None
	Sample Size: 250 mL

5

NY ENVIRONMENTAL
88 HARBOR ROAD PORT WASHINGTON, NY 11050

CONSULTANT INFORMATION

Name: New York Environmental
Address: 88 Harbor Road Pt Wash
Project Manager: Baudo

PROJECT INFORMATION

BLDG ID: q144
BLDG Name: P.S. 144 - QUEENS
Address: 93-02 69 AVENUE, QUEENS, NY
WO # 48426

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
OUT-OF-ORDER O
YELLOW TAG T
MISCELLANEOUS M

	(ppb)			(ppb)	
49 1ST COC Q144 04 FL BOYS BATHROOM 000459 COLD WATER FAUCET 2 DATE 1-26-17 TIME 0350	2.5	I O T M	Out of service		I O T M
50 1ST COC Q144 04 FL BOYS BATHROOM 000459 COLD WATER FAUCET 3 DATE 1-26-17 TIME 0352	<1.0	I O T M	Out of service		I O T M
51 1ST COC Q144 04 FL CLASSROOM 000419 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0359		I O T M		51 1ST COC Q144 04 FL OFFICE 000460 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0355	I O T M
52 1ST COC Q144 04 FL GYMNASIUM 000454 COLD WATER FAUCET 1 DATE 1-26-17 TIME 0343		I O T M			I O T M
53 Out of service		I O T M			I O T M
54 1ST COC Q144 04 FL HALLWAY 000461 BUBBLER 1 DATE 1-26-17 TIME 0357	1.1	I O T M			I O T M

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>[Signature]</i>	<i>[Signature]</i>	1-26-17	9W
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <u>NY ENVIRONMENTAL</u>	Method of Analysis: <u>200.9 REV 2.2</u>
Analyzed By: <u>WAT S Wey</u>	Date: <u>1/27/17</u> Time: <u>1700</u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u>None</u> Sample Size: <u>250 mL</u>