



**Department of  
Education**

*Carmen Fariña, Chancellor*

**Elizabeth A. Rose** February 7, 2017

Deputy Chancellor

Division of Operations Dear Families and Staff:

**52 Chambers Street  
New York, NY 10007**

**212 374 7868** Tel

**212 374 5588** Fax

This is a follow up to my December 19 letter outlining the additional measures the New York City Department of Education (DOE) is taking to ensure that the water in New York City schools is safe for students and staff.

On **January 28, 2017**, every potential source of water for drinking or preparing food at **Mnht Comp Night&Day (OI Bacn X)-M** (Manhattan Comprehensive Night and Day High School, 240 2 Avenue Manhattan, NY 10003) was tested for lead. The laboratory results showed elevated levels of lead in **4 of the 33 samples** of water taken and tested from outlets in the building. A more detailed letter related to the testing for lead at Mnht Comp Night&Day (OI Bacn X)-M is attached and complete test results are posted on the DOE website.

In any building where lead test results show even one water outlet above the action level of 15 parts per billion, the DOE will implement its standard response protocol, which includes removing any drinking or cooking water fixture outlet from service, flushing all or part of the system to eliminate water sitting in pipes overnight, replacing equipment and re-testing after the equipment is replaced.

Each affected drinking or cooking water fixture at Mnht Comp Night&Day (OI Bacn X)-M will remain out of service until it is remediated and future testing shows that the water does not have an elevated level of lead. The custodial staff will also continue to flush the Mnht Comp Night&Day (OI Bacn X)-M water systems on Monday mornings before school starts in order to eliminate water that has been stagnant in pipes over the weekend and to ensure safe drinking water is available for students and staff.

Please visit <http://schools.nyc.gov/AboutUs/schools/watersafety.htm> to learn more about the robust protocol we use to ensure the safety of drinking water in each and every school, as well as to look up water test results for their child's school.

We will keep you updated on the remediation work at Mnht Comp Night&Day (OI Bacn X)-M, and thank you for your patience and support.

Sincerely yours,

Elizabeth A. Rose



**A NOTICE TO PARENTS, GUARDIANS, AND STAFF**  
**Mnht Comp Night&Day (OI Bacn X)-M**  
**Manhattan Comprehensive Night and Day High School**  
**240 2 Avenue Manhattan, NY 10003**  
**LEAD TESTING OF SCHOOL DRINKING WATER**  
*February 7, 2017*

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 15 parts per billion (ppb), which is equal to 15 micrograms per liter (µg/L), the NYSDOH requires that the school take action to reduce the exposure to lead.

**What is first draw testing of school drinking water for lead?**

The “on-again, off-again” nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This “first draw” sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

**What are the results of the first draw testing?**

Samples Collected on 01/28/2017				
Floor	Function / Space	Room	Fixture Type	Sample Results
02	HALLWAY	204	BUBBLER 1	66.1 ppb
06	GIRLS BATHROOM	609	COLD WATER FAUCET 2	44.4 ppb
BS	HALLWAY	5	BUBBLER 1	19.7 ppb
BS	HALLWAY	5	BUBBLER 2	72.5 ppb

**What is being done in response to the results?**

Outlets that tested with lead levels above the action level (15 ppb) at Mnht Comp Night&Day (OI Bacn X)-M have been taken out of service and will be replaced. Each of the affected fixtures will remain out of service until remediation work is completed and future testing provides results below the action level.

**What are the health effects of lead?**

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

**What are the other sources of lead exposure?**

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and



**Department of  
Education**

*Carmen Fariña, Chancellor*

cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

### **Should your child be tested for lead?**

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

### **Do elevated lead levels in school drinking water pose a serious risk to students and staff?**

The risk to students and staff is low for many reasons. The elevated lead levels identified by the recent round of water testing are not likely to represent the levels seen throughout the day. The recent testing was conducted on water that had remained in pipes overnight. The lead concentration drops sharply after the first use of the day as stagnant water is cleared from the pipes and new, fresh water is brought in from the water main – which is virtually lead-free. In addition, for most students and staff, the amount of water consumed from a school water source during a school day is likely to be small when compared to total daily water consumption. Many of the elevated water samples came from fixtures that are not typically used for drinking, including bathrooms, slop sinks, and laboratories. Given all of these factors it is unlikely that these elevations represent conditions that would pose a health risk, however, if a person drinks sufficiently large quantities of water at those high levels over long periods of time, the risk increases. Nonetheless, if you are concerned about exposure to lead, talk to your doctor about having you or your child tested for lead poisoning.

### **Who is at risk for lead poisoning?**

Children under 3 years of age are the most susceptible and vulnerable to the health effects of lead. Lead also poses a risk to the developing fetus. Exposure to lead may interfere with a child's growth and development.

### **What do we know about rates of lead poisoning in NYC children?**

Rates of lead poisoning among NYC children have been falling. In 2015, 5,371 New York City children younger than 6 years of age were identified with blood lead levels of 5 mcg/dL or greater. This represents an 18% decline from 2014 when there were 6,550 children with blood lead levels of 5 mcg/dL or greater, and an 86% decline since 2005 when there were 37,344 children with blood lead levels of 5mcg/dL or greater.

### **Additional Resources**

**For more information regarding the testing program or sampling results go to:**

<http://schools.nyc.gov/AboutUs/schools/watersafety.htm>

For information about lead in school drinking water, go to:

[http://www.health.ny.gov/environmental/water/drinking/lead/lead\\_testing\\_of\\_school\\_drinking\\_water.htm](http://www.health.ny.gov/environmental/water/drinking/lead/lead_testing_of_school_drinking_water.htm)

<http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html>

**For information about NYS Department of Health Lead Poisoning Prevention, go to:**

<http://www.health.ny.gov/environmental/lead/>

**For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means":**

<http://www.health.ny.gov/publications/2526/> (available in ten languages).



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Jon Vafiadis**  
**Precision Environmental**  
**36-15 A 23rd Street**  
**2nd floor**  
**Long Island City, NY 11106**

2/3/2017

Phone: (718) 383-2626  
Fax: (718) 383-7780

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/31/2017. The results are tabulated on the attached data pages for the following client designated project:

**M661/ MNHT Comp Night & Day (OI Bacn X) - M/ 240 2nd Avenue/  
New York/ PEI Project #: 2181-16-0407**

The reference number for these samples is EMSL Order #011700813. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011700813

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**  
**Precision Environmental**  
**36-15 A 23rd Street**  
**2nd floor**  
**Long Island City, NY 11106**

Phone: (718) 383-2626  
 Fax: (718) 383-7780  
 Received: 01/31/17 7:00 AM

Project: **M661/ MNHT Comp Night & Day (OI Bacn X) - M/ 240 2nd Avenue/ New York/ PEI Project #: 2181-16-0407**

**Analytical Results**

**Client Sample Description** 1CM661BSBR00006.1F-001 **Collected:** 1/28/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM661BSHA00005.1B-002 **Collected:** 1/28/2017 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.7	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM661BSHA00005.2B-003 **Collected:** 1/28/2017 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	72.5	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66101BR000103.1F-004 **Collected:** 1/28/2017 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66102BR000201.1F-006 **Collected:** 1/28/2017 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.91	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66102GB000201.1F-007 **Collected:** 1/28/2017 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66102GB000201.2F-008 **Collected:** 1/28/2017 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011700813

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**  
**Precision Environmental**  
**36-15 A 23rd Street**  
**2nd floor**  
**Long Island City, NY 11106**

Phone: (718) 383-2626  
 Fax: (718) 383-7780  
 Received: 01/31/17 7:00 AM

Project: **M661/ MNHT Comp Night & Day (OI Bacn X) - M/ 240 2nd Avenue/ New York/ PEI Project #: 2181-16-0407**

**Analytical Results**

**Client Sample Description** 1CM66102GB000201.3F-009 **Collected:** 1/28/2017 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66102GB000201.4F-010 **Collected:** 1/28/2017 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66102HA000204.1B-011 **Collected:** 1/28/2017 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	66.1	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66102HA000204.2B-012 **Collected:** 1/28/2017 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.59	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66103BB000304.1F-013 **Collected:** 1/28/2017 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66103BB000304.2F-014 **Collected:** 1/28/2017 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66103HA000304.1B-015 **Collected:** 1/28/2017 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011700813

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**  
**Precision Environmental**  
**36-15 A 23rd Street**  
**2nd floor**  
**Long Island City, NY 11106**

Phone: (718) 383-2626  
 Fax: (718) 383-7780  
 Received: 01/31/17 7:00 AM

Project: **M661/ MNHT Comp Night & Day (OI Bacn X) - M/ 240 2nd Avenue/ New York/ PEI Project #: 2181-16-0407**

**Analytical Results**

**Client Sample Description** 1CM66103HA000304.2B-016 **Collected:** 1/28/2017 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66104BR000400.1F-017 **Collected:** 1/28/2017 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.25	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66104CR000405.1F-019 **Collected:** 1/28/2017 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.2	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66104HA000404.1B-020 **Collected:** 1/28/2017 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66104HA000404.2B-021 **Collected:** 1/28/2017 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66105BR000505.1F-022 **Collected:** 1/28/2017 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.38	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66105HA000602.1B-024 **Collected:** 1/28/2017 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011700813

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**  
**Precision Environmental**  
**36-15 A 23rd Street**  
**2nd floor**  
**Long Island City, NY 11106**

Phone: (718) 383-2626  
 Fax: (718) 383-7780  
 Received: 01/31/17 7:00 AM

Project: M661/ MNHT Comp Night &amp; Day (OI Bacn X) - M/ 240 2nd Avenue/ New York/ PEI Project #: 2181-16-0407

**Analytical Results**

**Client Sample Description** 1CM66105KI000505.1F-025 **Collected:** 1/28/2017 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66105KI000505.2F-026 **Collected:** 1/28/2017 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66105KI000505.3F-027 **Collected:** 1/28/2017 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.05	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66105KI000505.4F-028 **Collected:** 1/28/2017 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.57	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66105KI000505.5F-029 **Collected:** 1/28/2017 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.00	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66106BB000609.1F-030 **Collected:** 1/28/2017 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.86	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66106BB000609.2F-031 **Collected:** 1/28/2017 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.07	1.00	µg/L	1/31/2017	CB	1/31/2017	BB



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011700813

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**  
**Precision Environmental**  
**36-15 A 23rd Street**  
**2nd floor**  
**Long Island City, NY 11106**

Phone: (718) 383-2626  
 Fax: (718) 383-7780  
 Received: 01/31/17 7:00 AM

Project: **M661/ MNHT Comp Night & Day (OI Bacn X) - M/ 240 2nd Avenue/ New York/ PEI Project #: 2181-16-0407**

**Analytical Results**

**Client Sample Description** 1CM66106GB000609.1F-032 **Collected:** 1/28/2017 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.82	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66106GB000609.2F-033 **Collected:** 1/28/2017 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	44.4	1.00	µg/L	2/2/2017	CB	2/2/2017	BB

**Client Sample Description** 1CM66106HA000602.1B-034 **Collected:** 1/28/2017 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.46	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Client Sample Description** 1CM66106HA000602.2B-035 **Collected:** 1/28/2017 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.78	1.00	µg/L	2/1/2017	CB	2/1/2017	EG

**Client Sample Description** 1CM66106OF000610.1F-066 **Collected:** 1/28/2017 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/31/2017	CB	1/31/2017	BB

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

**CONSULTANT INFORMATION**

Name: Precision Environmental Inc.  
 Address: 36-15A 23rd Street, LIC, NY 11106  
 Project Manager: Jon Vafiadis  
 PEI Project#: 2181-16-0407

**PROJECT INFORMATION**

BLDG ID: M661  
 BLDG Name: MNHT COMP NIGHT&DAY (OL BACN X)-M  
 BLDG Address: 240 2ND AVENUE  
 WO # New York

**NON-SAMPLABLE OUTLET LEGEND**

INACCESSIBLE I  
 OUT-OF-ORDER O  
 YELLOW TAG T  
 MISCELLANEOUS M

(ppb)			(ppb)	
1ST COC M661 BS FL ADULT BATHROOM 00006 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0202		I O T M	1ST COC M661 02 FL GIRLS BATHROOM 000201 COLD WATER FAUCET 2  DATE 1/28/17 TIME 0228	I O T M
1ST COC M661 BS FL HALLWAY 00005 BUBBLER 1  DATE 1/28/17 TIME 0203		I O T M	1ST COC M661 02 FL GIRLS BATHROOM 000201 COLD WATER FAUCET 3  DATE 1/28/17 TIME 0229	I O T M
1ST COC M661 BS FL HALLWAY 00005 BUBBLER 2  DATE 1/28/17 TIME 0200		I O T M	1ST COC M661 02 FL GIRLS BATHROOM 000201 COLD WATER FAUCET 4  DATE 1/28/17 TIME 0230	I O T M
1ST COC M661 01 FL ADULT BATHROOM 000103 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0214		I O T M	1ST COC M661 02 FL HALLWAY 000204 BUBBLER 1  DATE 1/28/17 TIME 0232	I O T M
1ST COC M661 02 FL ADULT BATHROOM 000201 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0224		I O T M	1ST COC M661 02 FL HALLWAY 000204 BUBBLER 2  DATE 1/28/17 TIME 0237	I O T M
1ST COC M661 02 FL GIRLS BATHROOM 000201 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0227		I O T M	1ST COC M661 03 FL BOYS BATHROOM 000304 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0214	I O T M

**CHAIN OF CUSTODY**

Relinquished By:	Received By:	Date:	Time:
1 Ricardo Valtair		1/30/17	4:20pm
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

**LABORATORY INFORMATION**

Laboratory Name: EMSL Analytical	Method of Analysis: 200.8
Analyzed By: Barbara Biddle	Date: 1/31/2017
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: Sample Size: 250 mL

rec'd by Steven Lopez on 1/31/17 @ 7:00am 20.8

**CONSULTANT INFORMATION**

Name: Precision Environmental Inc.  
 Address: 36-15A 23rd Street, LIC, NY 11106  
 Project Manager: Jon Vafiadis  
 PEI Project#: 2181-16-0407

**PROJECT INFORMATION**

BLDG ID: M661  
 BLDG Name: MNHT COMP NIGHT&DAY (OL BACN X)-M  
 BLDG Address: 240 2ND AVENUE  
 WO # New York

**NON-SAMPLABLE OUTLET LEGEND**

INACCESSIBLE I  
 OUT-OF-ORDER O  
 YELLOW TAG T  
 MISCELLANEOUS M

(ppb)				(ppb)			
1ST COC M661 03 FL BOYS BATHROOM 000304 COLD WATER FAUCET 2  DATE 1/28/17 TIME 0245		I O T M	13	1ST COC M661 04 FL HALLWAY 000404 BUBBLER 2  DATE 1/28/17 TIME 0257		I O T M	19
1ST COC M661 03 FL HALLWAY 000304 BUBBLER 1  DATE 1/28/17 TIME 0248		I O T M	14	1ST COC M661 05 FL ADULT BATHROOM 000505 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0314		I O T M	20
1ST COC M661 03 FL HALLWAY 000304 BUBBLER 2  DATE 1/28/17 TIME 0249		I O T M	15	1ST COC M661 05 FL HALLWAY 000502 BUBBLER 1  DATE 1/28/17 TIME 0319		I O T M	21
1ST COC M661 04 FL ADULT BATHROOM 000400 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0255		I O T M	16	1ST COC M661 05 FL KITCHEN 000505 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0323		I O T M	22
1ST COC M661 04 FL CLASSROOM 000405 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0301		I O T M	17	1ST COC M661 05 FL KITCHEN 000505 COLD WATER FAUCET 2  DATE 1/28/17 TIME 0324		I O T M	23
1ST COC M661 04 FL HALLWAY 000404 BUBBLER 1  DATE 1/28/17 TIME 0306		I O T M	18	1ST COC M661 05 FL KITCHEN 000505 COLD WATER FAUCET 3  DATE 1/28/17 TIME 0326		I O T M	24

**CHAIN OF CUSTODY**

Relinquished By:	Received By:	Date:	Time:
1 Ricardo Voltaire			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

**LABORATORY INFORMATION**

Laboratory Name: EMSL Analytical	Method of Analysis: 200.8
Analyzed By: Barbara Biddle	Date: 1/31/2017 Time:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: Sample Size: 250 mL

rec'd by Steven Lopez on 1/31/17 @ 7:00am 20.8

**CONSULTANT INFORMATION**

Name: Precision Environmental Inc.  
 Address: 36-15A 23rd Street, LIC, NY 11106  
 Project Manager: Jon Vafiadis  
 PEI Project#: 2181-16-0407

**PROJECT INFORMATION**

BLDG ID: M661  
 BLDG Name: MNHT COMP NIGHT&DAY (OL BACN X)-M  
 BLDG Address: 240 2ND AVENUE  
 WO # New York

**NON-SAMPLABLE OUTLET LEGEND**

INACCESSIBLE I  
 OUT-OF-ORDER O  
 YELLOW TAG T  
 MISCELLANEOUS M

(ppb)			(ppb)
1ST COC M661 05 FL KITCHEN 000505 COLD WATER FAUCET 4  DATE 1/28/17 TIME 0329	I O T M	25	1ST COC M661 06 FL HALLWAY 000602 BUBBLER 1  DATE 1/28/17 TIME 0350
1ST COC M661 05 FL KITCHEN 000505 COLD WATER FAUCET 5  DATE 1/28/17 TIME 0333	I O T M	26	1ST COC M661 06 FL HALLWAY 000602 BUBBLER 2  DATE 1/28/17 TIME 0351
1ST COC M661 06 FL BOYS BATHROOM 000609 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0341	I O T M	27	1ST COC M661 06 FL OFFICE 000610 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0359
1ST COC M661 06 FL BOYS BATHROOM 000609 COLD WATER FAUCET 2  DATE 1/28/17 TIME 0342	I O T M	28	
1ST COC M661 06 FL GIRLS BATHROOM 000609 COLD WATER FAUCET 1  DATE 1/28/17 TIME 0345	I O T M	29	
1ST COC M661 06 FL GIRLS BATHROOM 000609 COLD WATER FAUCET 2  DATE 1/28/17 TIME 0346	I O T M	30	
	I O T M		
	I O T M		

**CHAIN OF CUSTODY**

Relinquished By:	Received By:	Date:	Time:
1 Ricardo Vourakis			
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

<b>LABORATORY INFORMATION</b>		Method of Analysis: 200.8
Laboratory Name: EMSL Analytical	Analyzed By: Barbara Biddle / Eric Gaskill	Date: 1/31/2017, 2/1/2017
Note: No sample submitted if "I", "O", "T", or "M" check-marked.		Preservative: Sample Size: 250 mL

rec'd by Steven Lopez on 1/31/17 @ 7:00am 20.8