



Elizabeth A. Rose
Deputy Chancellor
Division of Operations

52 Chambers Street
New York, NY 10007

212 374 7868 Tel
212 374 5588 Fax

April 20, 2017

Dear Families and Staff:

This is a follow up to my December 19 letter outlining the additional measures the New York City Department of Education (DOE) is taking to ensure that the water in New York City schools is safe for students and staff.

On **January 19, 2017**, every potential source of water for drinking or preparing food at **New Sch For Arts And Science - X (Holcombe L. Rucker School of Community Research, 965 Longwood Avenue Bronx, NY 10459)** was tested for lead. The laboratory results showed no elevated levels of lead in any of the samples of at **New Sch For Arts And Science - X**.

This letter and the full lab report can be viewed on the Holcombe L. Rucker School of Community Research website (<http://schools.nyc.gov/schoolportals/08/X332/default.htm>).

Please visit <http://schools.nyc.gov/AboutUs/schools/watersafety.htm> to learn more about the robust protocol we use to ensure the safety of drinking water in each and every school.

Thank you for your support and we wish you and your students a wonderful remainder of the school year.

Sincerely yours,

A handwritten signature in black ink that reads 'Elizabeth A. Rose'. The signature is fluid and cursive, with the first name being the most prominent.

Elizabeth A. Rose



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Jon Vafiadis
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

1/24/2017

Phone: (718) 383-2626
Fax: (718) 383-7780

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/20/2017. The results are tabulated on the attached data pages for the following client designated project:

**X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/
Bronx/ 2181-17-0430**

The reference number for these samples is EMSL Order #011700475. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX039BSBR000B12.1F-001 **Collected:** 1/19/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.82	1.00	µg/L	1/20/2017	AE	1/23/2017	EG

Client Sample Description 1CX039BSBR000B9C.1F-002 **Collected:** 1/19/2017 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSBB000BO1.1F-003 **Collected:** 1/19/2017 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.27	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSBB000BO1.2F-004 **Collected:** 1/19/2017 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.06	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSBB000BO1.3F-005 **Collected:** 1/19/2017 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.01	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSCF000B11.1F-006 **Collected:** 1/19/2017 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSKI0000B8.1F-009 **Collected:** 1/19/2017 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX039BSKI0000B8.2F-010 **Collected:** 1/19/2017 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSMO000B10.1F-011 **Collected:** 1/19/2017 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSMO000B10.2F-012 **Collected:** 1/19/2017 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSMO000B10.3F-013 **Collected:** 1/19/2017 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.63	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSMO000B10.4F-014 **Collected:** 1/19/2017 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSMO000B10.5F-015 **Collected:** 1/19/2017 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.07	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSMO000B10.6F-016 **Collected:** 1/19/2017 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.65	1.00	µg/L	1/23/2017	CB	1/23/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX039BSMO000B10.7F-017 **Collected:** 1/19/2017 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSOF000B15.1F-018 **Collected:** 1/19/2017 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.29	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX039BSOF000B9A.1F-019 **Collected:** 1/19/2017 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.90	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901BR000104.1F-020 **Collected:** 1/19/2017 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.57	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901BR00150A.1F-021 **Collected:** 1/19/2017 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.21	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901BB000104.1F-022 **Collected:** 1/19/2017 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.54	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901BB000104.2F-023 **Collected:** 1/19/2017 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.57	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX03901BB000104.3F-024 **Collected:** 1/19/2017 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.03	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901CR000107.1F-025 **Collected:** 1/19/2017 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.17	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901CR000110.1F-026 **Collected:** 1/19/2017 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.6	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901CR000117.1F-028 **Collected:** 1/19/2017 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901GB000111.1F-029 **Collected:** 1/19/2017 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901GB000111.2F-030 **Collected:** 1/19/2017 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901HA00104A.1B-031 **Collected:** 1/19/2017 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.09	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX03901HA00104A.2B-032 **Collected:** 1/19/2017 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901HA000106.1B-033 **Collected:** 1/19/2017 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.32	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901HA000115.1B-034 **Collected:** 1/19/2017 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901HA000115.2B-035 **Collected:** 1/19/2017 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.91	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901OF00104A.1F-036 **Collected:** 1/19/2017 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03901WR000115.1F-037 **Collected:** 1/19/2017 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902BR00204B.1F-038 **Collected:** 1/19/2017 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.50	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX03902BR00215A.1F-039 **Collected:** 1/19/2017 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.37	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902CR000210.1F-040 **Collected:** 1/19/2017 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.95	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902GB000208.1F-041 **Collected:** 1/19/2017 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902GB000208.2F-042 **Collected:** 1/19/2017 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902HA000204.1B-043 **Collected:** 1/19/2017 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902HA000204.2B-044 **Collected:** 1/19/2017 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902HA000209.1B-045 **Collected:** 1/19/2017 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX03902HA000209.2B-046 **Collected:** 1/19/2017 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902HA000215.1B-047 **Collected:** 1/19/2017 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.46	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902HA000215.2B-048 **Collected:** 1/19/2017 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.40	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902OF00204A.1F-049 **Collected:** 1/19/2017 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.52	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03902SS000209.1F-050 **Collected:** 1/19/2017 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903BR000303.1F-051 **Collected:** 1/19/2017 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.97	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903BR00315A.1F-052 **Collected:** 1/19/2017 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.18	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX03903GB000311.1F-053 **Collected:** 1/19/2017 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903GB000311.2F-054 **Collected:** 1/19/2017 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903HA000304.1B-055 **Collected:** 1/19/2017 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.15	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903HA000304.2B-056 **Collected:** 1/19/2017 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903HA000306.1B-057 **Collected:** 1/19/2017 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.07	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903HA000306.2B-058 **Collected:** 1/19/2017 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.06	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903HA00315A.1B-059 **Collected:** 1/19/2017 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.14	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700475

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 01/20/17 9:00 AM

Project: X039/ New Sch for Arts and Science - X/ 965 Longwood Avenue/ Bronx/ 2181-17-0430

Analytical Results

Client Sample Description 1CX03903HA00315A.2B-060 **Collected:** 1/19/2017 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903SS000309.1F-061 **Collected:** 1/19/2017 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.35	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Client Sample Description 1CX03903TC000314.1F-062 **Collected:** 1/19/2017 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.19	1.00	µg/L	1/20/2017	AE	1/20/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0430

PROJECT INFORMATION

BLDG ID: X039
 BLDG Name: NEW SCH FOR ARTS AND SCIENCE - X
 BLDG Address: 965 LONGWOOD AVENUE
 WO # Bronx

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

(ppb)			(ppb)
1ST COC X039 BS FL ADULT BATHROOM 000B12 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0230		I O T M 1	1ST COC X039 BS FL KITCHEN 0000B8 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0253
1ST COC X039 BS FL ADULT BATHROOM 000B9C COLD WATER FAUCET 1 DATE 01/19/17 TIME 0234		I O T M 2	1ST COC X039 BS FL KITCHEN 0000B8 COLD WATER FAUCET 2 DATE 01/19/17 TIME 0255
1ST COC X039 BS FL BOYS BATHROOM 000B01 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0238		I O T M 3	1ST COC X039 BS FL MEDICAL OFFICE 000B10 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0258
1ST COC X039 BS FL BOYS BATHROOM 000B01 COLD WATER FAUCET 2 DATE 01/19/17 TIME 0242		I O T M 4	1ST COC X039 BS FL MEDICAL OFFICE 000B10 COLD WATER FAUCET 2 DATE 01/19/17 TIME 0300
1ST COC X039 BS FL BOYS BATHROOM 000B01 COLD WATER FAUCET 3 DATE 01/19/17 TIME 0244		I O T M 5	1ST COC X039 BS FL MEDICAL OFFICE 000B10 COLD WATER FAUCET 3 DATE 01/19/17 TIME 0303
1ST COC X039 BS FL CAFETERIA 000B11 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0248		I O T M 6	1ST COC X039 BS FL MEDICAL OFFICE 000B10 COLD WATER FAUCET 4 DATE 01/19/17 TIME 0306

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>By George Adams</i>	<i>Sandy Johnson</i>	<i>1/19/17</i>	<i>8pm</i>
2	<i>AM COURIER</i>		
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:
Analyzed By:	Date:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time: <i>8pm</i>
	Preservative:
	Sample Size: 250 mL

rec'd by Steven Lopez on 1/20/17 @ 9:00am 20.6

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0430

PROJECT INFORMATION

BLDG ID: X039
 BLDG Name: NEW SCH FOR ARTS AND SCIENCE - X
 BLDG Address: 965 LONGWOOD AVENUE
 WO # Bronx

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

(ppb)			(ppb)			
1ST COC X039 BS FL MEDICAL OFFICE 000B10 COLD WATER FAUCET 5 DATE <u>01/19/17</u> TIME <u>0308</u>		I O T M	13	1ST COC X039 01 FL ADULT BATHROOM 00150A COLD WATER FAUCET 1 DATE <u>01/19/17</u> TIME <u>0330</u>	I O T M	19
1ST COC X039 BS FL MEDICAL OFFICE 000B10 COLD WATER FAUCET 6 DATE <u>01/19/17</u> TIME <u>0310</u>		I O T M	14	1ST COC X039 01 FL BOYS BATHROOM 000104 COLD WATER FAUCET 1 DATE <u>01/19/17</u> TIME <u>0333</u>	I O T M	20
1ST COC X039 BS FL MEDICAL OFFICE 000B10 COLD WATER FAUCET 7 DATE <u>01/19/17</u> TIME <u>0314</u>		I O T M	15	1ST COC X039 01 FL BOYS BATHROOM 000104 COLD WATER FAUCET 2 DATE <u>01/19/17</u> TIME <u>0335</u>	I O T M	21
1ST COC X039 BS FL OFFICE 000B15 COLD WATER FAUCET 1 DATE <u>01/19/17</u> TIME <u>0318</u>		I O T M	16	1ST COC X039 01 FL BOYS BATHROOM 000104 COLD WATER FAUCET 3 DATE <u>01/19/17</u> TIME <u>0337</u>	I O T M	22
1ST COC X039 BS FL OFFICE 000B9A COLD WATER FAUCET 1 DATE <u>01/19/17</u> TIME <u>0322</u>		I O T M	17	1ST COC X039 01 FL CLASSROOM 000107 COLD WATER FAUCET 1 DATE <u>01/19/17</u> TIME <u>0341</u>	I O T M	23
1ST COC X039 01 FL ADULT BATHROOM 000104 COLD WATER FAUCET 1 DATE <u>01/19/17</u> TIME <u>0325</u>		I O T M	18	1ST COC X039 01 FL CLASSROOM 000110 COLD WATER FAUCET 1 DATE <u>01/19/17</u> TIME <u>0344</u>	I O T M	24

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <u>George Alenzi</u>	<u>Denny Bobson</u>	<u>1/19/2016</u>	<u>4:16 PM</u>
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:
Analyzed By:	Date:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time:
	Preservative:
	Sample Size: 250 mL

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0430

PROJECT INFORMATION

BLDG ID: X039
 BLDG Name: NEW SCH FOR ARTS AND SCIENCE - X
 BLDG Address: 965 LONGWOOD AVENUE
 WO # Bronx

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

	(ppb)			(ppb)		
1ST COC X039 01 FL CLASSROOM 000117 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0348		I O T M	25	1ST COC X039 01 FL HALLWAY 000115 BUBBLER 1 DATE 01/19/17 TIME 0348	I O T M	31
1ST COC X039 01 FL GIRLS BATHROOM 000111 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0352		I O T M	26	1ST COC X039 01 FL HALLWAY 000115 BUBBLER 2 DATE 01/19/17 TIME 0400	I O T M	32
1ST COC X039 01 FL GIRLS BATHROOM 000111 COLD WATER FAUCET 2 DATE 01/19/17 TIME 0354		I O T M	27	1ST COC X039 01 FL OFFICE 00104A COLD WATER FAUCET 1 DATE 01/19/17 TIME 0414	I O T M	33
1ST COC X039 01 FL HALLWAY 00104A BUBBLER 1 DATE 01/19/17 TIME 0358		I O T M	28	1ST COC X039 01 FL WEIGHT ROOM 000115 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0407	I O T M	34
1ST COC X039 01 FL HALLWAY 00104A BUBBLER 2 DATE 01/19/17 TIME 0400		I O T M	29	1ST COC X039 02 FL ADULT BATHROOM 00204B COLD WATER FAUCET 1 DATE 01/19/17 TIME 0420	I O T M	35
1ST COC X039 01 FL HALLWAY 000106 BUBBLER 1 DATE 01/19/17 TIME 0405		I O T M	30	1ST COC X039 02 FL ADULT BATHROOM 00215A COLD WATER FAUCET 1 DATE 01/19/17 TIME 0423	I O T M	36

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>By George Adams</i>	<i>Demoy Baden</i>	<i>1/19/17</i>	<i>4:00 PM</i>
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:
Analyzed By:	Date:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time:
	Preservative:
	Sample Size: 250 mL

RECEIVED
 1/19/17
 4:00 PM

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0430

PROJECT INFORMATION

BLDG ID: X039
 BLDG Name: NEW SCH FOR ARTS AND SCIENCE - X
 BLDG Address: 965 LONGWOOD AVENUE
 WO # Bronx

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)			(ppb)		
1ST COC X039 02 FL CLASSROOM 000210 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0427		I O T M 37	1ST COC X039 02 FL HALLWAY 000209 BUBBLER 2 DATE 01/19/17 TIME 0444		I O T M 43
1ST COC X039 02 FL GIRLS BATHROOM 000208 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0430		I O T M 38	1ST COC X039 02 FL HALLWAY 000215 BUBBLER 1 DATE 01/19/17 TIME 0447		I O T M 44
1ST COC X039 02 FL GIRLS BATHROOM 000208 COLD WATER FAUCET 2 DATE 01/19/17 TIME 0432		I O T M 39	1ST COC X039 02 FL HALLWAY 000215 BUBBLER 2 DATE 01/19/17 TIME 0449		I O T M 45
1ST COC X039 02 FL HALLWAY 000204 BUBBLER 1 DATE 01/19/17 TIME 0436		I O T M 40	1ST COC X039 02 FL OFFICE 00204A COLD WATER FAUCET 1 DATE 01/19/17 TIME 0454		I O T M 46
1ST COC X039 02 FL HALLWAY 000204 BUBBLER 2 DATE 01/19/17 TIME 0438		I O T M 41	1ST COC X039 02 FL SLOP SINK CLOSET 000209 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0458		I O T M 47
1ST COC X039 02 FL HALLWAY 000209 BUBBLER 1 DATE 01/19/17 TIME 0442		I O T M 42	1ST COC X039 03 FL ADULT BATHROOM 000303 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0502		I O T M 48

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>H. George Adams</i>	<i>Henry Batson</i>	<i>1/19/17</i>	<i>4:16 PM</i>
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:
Analyzed By:	Date:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time:
	Preservative:
	Sample Size: 250 mL

RECEIVED
 2017 JAN 19 PM 4:16
 PRECISION ENVIRONMENTAL INC.

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0430

PROJECT INFORMATION

BLDG ID: X039
 BLDG Name: NEW SCH FOR ARTS AND SCIENCE - X
 BLDG Address: 965 LONGWOOD AVENUE
 WO # Bronx

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)			(ppb)				
1ST COC X039 03 FL ADULT BATHROOM 00315A COLD WATER FAUCET 1 DATE 01/19/17 TIME 0555		I O T M	49	1ST COC X039 03 FL HALLWAY 000306 BUBBLER 2 DATE 01/19/17 TIME 0522		I O T M	55
1ST COC X039 03 FL GIRLS BATHROOM 000311 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0559		I O T M	50	1ST COC X039 03 FL HALLWAY 00315A BUBBLER 1 DATE 01/19/17 TIME 0526		I O T M	56
1ST COC X039 03 FL GIRLS BATHROOM 000311 COLD WATER FAUCET 2 DATE 01/19/17 TIME 0511		I O T M	51	1ST COC X039 03 FL HALLWAY 00315A BUBBLER 2 DATE 01/19/17 TIME 0528		I O T M	57
1ST COC X039 03 FL HALLWAY 000304 BUBBLER 1 DATE 01/19/17 TIME 0515		I O T M	52	1ST COC X039 03 FL SLOP SINK CLOSET 000309 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0533		I O T M	38
1ST COC X039 03 FL HALLWAY 000304 BUBBLER 2 DATE 01/19/17 TIME 0517		I O T M	53	1ST COC X039 03 FL TEACHERS CAFETERIA 000314 COLD WATER FAUCET 1 DATE 01/19/17 TIME 0535		I O T M	59
1ST COC X039 03 FL HALLWAY 000306 BUBBLER 1 DATE 01/19/17 TIME 0520		I O T M	54			I O T M	

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>George Adunji</i>	<i>Denny Bohan</i>	<i>1/19/17</i>	<i>4:16 PM</i>
2			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:
Analyzed By:	Date:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time:
	Preservative:
	Sample Size: 250 mL